

EAST RENFREWSHIRE ACCESS PANEL

ACCESS GUIDE AUDIT FORM - abridged



PREMISES: **Barrhead Community Library**

ADDRESS: **Glen Street, Barrhead, G78 1QA**

TELEPHONE NUMBER: **0141-577-3518**

1. PARKING:

Disabled parking is found in Foundry Lane in front of the library. There are 3 spaces, about 39 metres from the entrance, awkward but accessible by wheelchair.

2. ACCESSIBILITY: EXTERNAL:

The surface to the entrance is tarmac and concrete with a severe incline. However, there is a ramp but steps (5) are there for pedestrians. The entrance doors are double and manual and they open to a width of 1.47 metres. There is a severe slope to the entrance. If Foundry Brae is too steep for disabled people, access to the library can be achieved from the top end of Glen Street by going to the back door of the library HQ and ringing the bell. A member of staff will take them down the HQ corridor to the library and escort them back when finished.

3. ACCESSIBILITY: INTERNAL:

There is only one floor inside, carpeted, and accessible by wheelchair. There is no evac-chair, but sensory provision is available and guide dogs are always welcome. The service can be brought to the customer if requested.

4. TOILETS:

There are toilets available for the public and a wheelchair accessible disabled toilet with a sensory facility available. Width of disabled cubicle is 860mm (adequate).

5. FURTHER DETAILS:

There is a manager's office, and opening hours are found under the general library information link near the top of the library access page.

6. DATE OF AUDIT: **July, 2005**
